

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1493:125 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: *Grinnell Fire Protection Systems, 835 Sharon Drive, Westlake OH 44145
Contact: R.D. McDonnell (216) 871-9900

DESIGN: Models 995-ILB In Line Booster, 996-RPA (Class A) and 997-RPB (Class B) Repeater Panels.
Each unit is comprised of separately listed subassemblies interconnected in such a way so as to provide for appropriate supervision and alarm signaling. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC primary, 24 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as notification appliance circuit boosters for use with separately listed compatible fire alarm control units.

NOTE: Formerly 7300-0077:123

*Rev. 09-05-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 19, 2001

*Listing Expires **June 30, 2002***

Authorized By:

BEN HO, Supervising Deputy
Program Manager